

Monitoring Period Begin Date	Monitoring Period End Date	DMR Received Date	Outfall *	Monitoring Location	Parameter Name	DMR Value ***	Permit Limit	Units	Statistical Base Code
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Temperature (°F)	77	110	°F	Instantaneous Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Color (Pt-Co Units)	12.5	100	Pt-Co Units	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	BOD5	0.62	467	lbs/day	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	BOD5	2.00	700	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	BOD5	0.66	934	lbs/day	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	BOD5	2.00	1400	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Influent	BOD5	54.94	Report	lbs/day	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Influent	BOD5	284.59	Report	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Influent	BOD5	72.80	Report	lbs/day	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Influent	BOD5	625.67	Report	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Chemical Oxygen Demand	22.76	571	lbs/day	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Chemical Oxygen Demand	74.50	856	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Chemical Oxygen Demand	27.98	1118	lbs/day	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Chemical Oxygen Demand	95.00	1675	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Influent	Chemical Oxygen Demand	85.70	Report	lbs/day	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Influent	Chemical Oxygen Demand	427.47	Report	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Influent	Chemical Oxygen Demand	109.81	Report	lbs/day	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Influent	Chemical Oxygen Demand	873.54	Report	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	pH	7.95	9.0	S.U.	Instantaneous Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	pH	6.90	6.0	S.U.	Instantaneous Minimum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Suspended Solids	1.04	20	lbs/day	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Suspended Solids	3.50	30	mg/L	Average Monthly

01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Suspended Solids	2.06	30	lbs/day	Weekly Average
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Suspended Solids	7.00	45	mg/L	Weekly Average
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Ammonia-Nitrogen	0.11	13	lbs/day	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Ammonia-Nitrogen	0.35	20.0	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Cyanide	0.00	1.2	lbs/day	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Cyanide	0.00	1.9	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Cyanide	0.00	2.5	lbs/day	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Cyanide	0.01	3.8	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Lithium	<0.05	Report	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Lithium	<0.05	Report	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Methyl Cellosolve	<6.70	40.6	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Methyl Cellosolve	<6.70	100	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	1,2-Dichloroethane	<0.001	0.1	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	1,2-Dichloroethane	<0.001	0.4	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Chloroform	<0.001	0.01	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Chloroform	<0.001	0.02	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Toluene	<0.001	0.02	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Toluene	<0.001	0.06	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Benzene	<0.001	0.02	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Benzene	<0.001	0.05	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Chlorobenzene	<0.001	0.06	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Chlorobenzene	<0.001	0.15	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Methylene Chloride	<0.003	0.3	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Methylene Chloride	<0.003	0.9	mg/L	Daily Maximum

01APR2014	30APR2014	28MAY2014	001A	Final Effluent	N-Nitrosodimethylamine	<0.002	0.008	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	N-Nitrosodimethylamine	<0.002	0.016	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	1,2-Dichlorobenzene	<0.001	0.06	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	1,2-Dichlorobenzene	<0.001	0.15	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Phenol	<0.0004	0.02	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Phenol	<0.0004	0.05	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Isopropyl Acetate	<0.001	0.5	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Isopropyl Acetate	<0.001	1.3	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Flow (mgd)	0.055	Report	MGD	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Flow (mgd)	0.083	Report	MGD	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Residual Chlorine (TRC)	0.05	0.5	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Residual Chlorine (TRC)	0.05	1.25	mg/L	Instantaneous Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Methyl Formate	<0.005	0.5	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Methyl Formate	<0.005	1.3	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Isobutyraldehyde	<0.001	0.5	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Isobutyraldehyde	<0.001	1.2	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	n-Amyl Acetate	<0.001	0.5	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	n-Amyl Acetate	<0.001	1.3	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Amyl Alcohol	<0.02	4.1	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Amyl Alcohol	<0.02	10.0	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Dissolved Solids	1646.60	13344	lbs/day	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Dissolved Solids	5483	20000	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Dissolved Solids	2511.88	26688	lbs/day	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Dissolved Solids	8529	40000	mg/L	Daily Maximum

01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Acetonitrile	<10.0	10.2	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Acetonitrile	<10.0	25	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Ethanol	<0.67	4.1	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Ethanol	<0.67	10.0	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Isopropanol	<0.025	1.6	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Isopropanol	<0.025	3.9	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Diethylamine	<17.0	102	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Diethylamine	<17.0	250	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Dimethyl Sulfoxide	<20.0	37.5	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Dimethyl Sulfoxide	<20.0	91.5	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Triethylamine	<17.0	102	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Triethylamine	<17.0	250	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Isopropyl Ether	<0.001	2.6	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Isopropyl Ether	<0.001	8.4	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	n-Butyl Acetate	<0.001	0.5	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	n-Butyl Acetate	<0.001	1.3	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Methanol	<0.67	4.1	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Methanol	<0.67	10.0	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	4-Methyl-2-pentanone	<0.001	0.2	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	4-Methyl-2-pentanone	<0.001	0.5	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Heptane	<0.002	0.02	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Heptane	<0.002	0.05	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Percent Removal	COD % Removal	100	74	%	Average
01APR2014	30APR2014	28MAY2014	001A	Percent Removal	BOD5 % Removal	100	90	%	Average

01APR2014	30APR2014	28MAY2014	001A	Percent Removal	BOD5 % Removal	100	85	%	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Xylenes	<0.002	0.01	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Total Xylenes	<0.002	0.03	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Acetone	<0.03	0.2	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Acetone	<0.03	0.5	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Ethyl Acetate	<0.002	0.5	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Ethyl Acetate	<0.002	1.3	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Hexane	<0.001	0.02	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Hexane	<0.001	0.03	mg/L	Daily Maximum
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Tetrahydrofuran	<0.02	2.6	mg/L	Average Monthly
01APR2014	30APR2014	28MAY2014	001A	Final Effluent	Tetrahydrofuran	<0.02	8.4	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Temperature (°F)	82.4	110	°F	Instantaneous Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Color (Pt-Co Units)	13.75	100	Pt-Co Units	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	BOD5	0.62	467	lbs/day	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	BOD5	2.00	700	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	BOD5	0.67	934	lbs/day	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	BOD5	2.00	1400	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Influent	BOD5	80.50	Report	lbs/day	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Influent	BOD5	460.06	Report	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Influent	BOD5	129.07	Report	lbs/day	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Influent	BOD5	578.70	Report	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Chemical Oxygen Demand	32.84	571	lbs/day	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Chemical Oxygen Demand	107.25	856	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Chemical Oxygen Demand	63.12	1118	lbs/day	Daily Maximum

01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Chemical Oxygen Demand	212.00	1675	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Influent	Chemical Oxygen Demand	118.38	Report	lbs/day	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Influent	Chemical Oxygen Demand	652.80	Report	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Influent	Chemical Oxygen Demand	206.64	Report	lbs/day	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Influent	Chemical Oxygen Demand	726.62	Report	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	pH	7.98	9.0	S.U.	Instantaneous Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	pH	6.78	6.0	S.U.	Instantaneous Minimum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Suspended Solids	0.94	20	lbs/day	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Suspended Solids	3.00	30	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Suspended Solids	1.01	30	lbs/day	Weekly Average
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Suspended Solids	3.00	45	mg/L	Weekly Average
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Ammonia-Nitrogen	0.07	13	lbs/day	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Ammonia-Nitrogen	0.23	20.0	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Cyanide	0.00	1.2	lbs/day	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Cyanide	0.01	1.9	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Cyanide	0.00	2.5	lbs/day	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Cyanide	0.01	3.8	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Lithium	<0.05	Report	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Lithium	<0.05	Report	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Methyl Cellosolve	<6.7	40.6	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Methyl Cellosolve	<6.7	100	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	1,2-Dichloroethane	<0.001	0.1	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	1,2-Dichloroethane	<0.001	0.4	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Chloroform	<0.001	0.01	mg/L	Average Monthly

01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Chloroform	<0.001	0.02	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Toluene	<0.001	0.02	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Toluene	<0.001	0.06	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Benzene	<0.001	0.02	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Benzene	<0.001	0.05	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Chlorobenzene	<0.001	0.06	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Chlorobenzene	<0.001	0.15	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Methylene Chloride	<0.003	0.3	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Methylene Chloride	<0.003	0.9	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	N-Nitrosodimethylamine	<0.002	0.008	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	N-Nitrosodimethylamine	<0.002	0.016	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	1,2-Dichlorobenzene	<0.001	0.06	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	1,2-Dichlorobenzene	<0.001	0.15	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Phenol	<0.0004	0.02	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Phenol	<0.0004	0.05	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Isopropyl Acetate	<0.001	0.5	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Isopropyl Acetate	<0.001	1.3	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Flow (mgd)	.056	Report	MGD	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Flow (mgd)	.081	Report	MGD	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Residual Chlorine (TRC)	0.02	0.5	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Residual Chlorine (TRC)	0.02	1.25	mg/L	Instantaneous Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Methyl Formate	<0.005	0.5	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Methyl Formate	<0.005	1.3	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Isobutyraldehyde	<0.001	0.5	mg/L	Average Monthly

01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Isobutyraldehyde	<0.001	1.2	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	n-Amyl Acetate	<0.001	0.5	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	n-Amyl Acetate	<0.001	1.3	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Amyl Alcohol	<0.02	4.1	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Amyl Alcohol	<0.02	10.0	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Dissolved Solids	1695.17	13344	lbs/day	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Dissolved Solids	5577.25	20000	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Dissolved Solids	3865.00	26688	lbs/day	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Dissolved Solids	12982.00	40000	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Acetonitrile	<10.0	10.2	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Acetonitrile	<10.0	25	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Ethanol	<0.67	4.1	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Ethanol	<0.67	10.0	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Isopropanol	<0.025	1.6	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Isopropanol	<0.025	3.9	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Diethylamine	<17.0	102	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Diethylamine	<17.0	250	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Dimethyl Sulfoxide	<20.0	37.5	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Dimethyl Sulfoxide	<20.0	91.5	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Triethylamine	<17.0	102	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Triethylamine	<17.0	250	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Isopropyl Ether	<0.001	2.6	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Isopropyl Ether	<0.001	8.4	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	n-Butyl Acetate	<0.001	0.5	mg/L	Average Monthly

01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	n-Butyl Acetate	<0.001	1.3	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Methanol	<0.67	4.1	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Methanol	<0.67	10.0	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	4-Methyl-2-pentanone	<0.001	0.2	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	4-Methyl-2-pentanone	<0.001	0.5	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Heptane	<0.002	0.02	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Heptane	<0.001	0.05	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Percent Removal	COD % Removal	100	74	%	Average
01MAY2014	31MAY2014	27JUN2014	001A	Percent Removal	BOD5 % Removal	100	90	%	Average
01MAY2014	31MAY2014	27JUN2014	001A	Percent Removal	BOD5 % Removal	100	85	%	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Xylenes	<0.002	0.01	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Total Xylenes	<0.002	0.03	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Acetone	<0.03	0.2	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Acetone	<0.03	0.5	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Ethyl Acetate	<0.002	0.5	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Ethyl Acetate	<0.002	1.3	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Hexane	<0.001	0.02	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Hexane	<0.001	0.03	mg/L	Daily Maximum
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Tetrahydrofuran	<0.02	2.6	mg/L	Average Monthly
01MAY2014	31MAY2014	27JUN2014	001A	Final Effluent	Tetrahydrofuran	<0.02	8.4	mg/L	Daily Maximum

Notes:

* **Outfall numbers include a *limit set designator* character at the end of a three digit number; the characters define the frequency at which DMRs are submitted.**

*** **DMR values may include "No Data Indicator" (NODI) Codes, which are characters that can be entered by permittees when data are not available. Possible NODI Codes include: A - exemption from monitoring for General**

Permits, B - data are below detection limits, C - there was no discharge, E - there was no sample(s) collected or no analysis(es) conducted, X - no data were reported, FF - there are other reasons for the absence of data (described in comments section of the report), and GG - monitoring is conditional and not required for reporting period.